

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7272-0694:254

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Fire Control Instruments, 301 2nd Ave., Waltham, MA 02451
Contact: Anthony Shalna (781) 471-3000 ext 3042

DESIGN: Models ASD-PL2 and ASD-PTL2 photoelectric smoke detector. Model MCS-ACCLIMATE2 employs a 135°F supplemental integral heat sensor which only assists in a fire situation. This thermal circuitry is NOT approved for use in lieu of a required heat detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's separately listed compatible fire alarm control units and bases. Suitable for open areas with air velocity between 0-4000 fpm. Models ASD-PL2, ASD-PTL2, AND MCS-ACCLIMATE2 are also suitable for installation inside ducts with a maximum air velocity of 4000 fpm.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires that consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

XLF: 7272-1209:160

9-28-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

SEPTEMBER 28, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager